Rye City Planning Commission Minutes December 14, 2004

ı					
2	PRESENT:				
3	Barbara Cummings, Chair				
4	Martha Monserrate, Vice-Chair				
5	Nick Everett (arrived late)				
6	Hugh Greechan				
7	_	Peter Larr			
8					
9	ABSENT:				
10	G. Patrick McGunagle				
11	H. Gerry Seitz				
12		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			
13	ALSO PRESENT:				
14	Christian K. Miller, AICP, City Planner				
15	George Mottarella, P.E., City Engineer				
16	Chantal Detlefs, City Naturalist				
17			, , , , , , , , , , , , , , , , , , ,		
18	I.	HEA	RINGS		
19					
20	1. McComb Residence				
21					
22	•	 Richard Horsman (applicant's landscape architect) provided an overview of the 			
23		project noting it involved the construction of an addition to a residence within the			
24			oot wetland buffer of Blind Brook.		
25					
26	•	• Horsman stated that as requested by the Commission the driveway that			
27		encroaches onto City of Rye property will be relocated to be completely on the			
28		applicant's property.			
29		• •	,		
30	 Horsman reviewed the mitigation planting plan and the drainage measures 				
31		which will treat storm water runoff from the addition in sub-surface cultec unit			
32	with an at grade overflow pipe.				
33					
34	There was no public comment.				
35			•		
36					
37	ACTI	ON:	Peter Larr made a motion, seco	onded by Hugh Greechan, that the	
38	Planning Commission close the public hearing on wetland pe			, ,	
39	application number WP159, which was carried by the following vote:			•	
40			, .	, 5	
41			Barbara Cummings, Chair:	Aye	
42			Martha Monserrate, Vice- Chair:	Aye	
43			Nick Everett:	Absent	
44			Hugh Greechan:	Aye	
45			G. Patrick McGunagle:	Absent	

December 14, 2004 Page 2 of 8

1 Peter Larr: Aye2 H. Gerry Seitz: Absent

II. ITEMS PENDING ACTION

1. McComb Residence

• Commission requested that the applicant be required to replace the driveway asphalt on City property with vegetation other than managed turf. The City Planner and City Naturalist should approve the landscape material.

• Commission reviewed the draft resolution of approval and requested minor changes clarifying the conditions.

ACTION: Peter Larr made a motion, seconded by Martha Monserrate, that the Planning Commission conditionally approve wetland permit application number WP159, which was carried by the following vote:

Barbara Cummings, Chair:

Martha Monserrate, Vice- Chair:

Nick Everett:

Hugh Greechan:

G. Patrick McGunagle:

Peter Larr:

H. Gerry Seitz:

Aye

Absent

Aye

Absent

Commission member Everett arrived at the meeting.

2. Community Synagogue of Rye

 Jonathan Kraut (applicant's attorney) provided an overview of the application noting that it involved removing the previously approved caretaker's residence, modifying the size and configuration of the children's play area and expanding the parking area to create 12 additional overflow parking spaces to be limited to seasonal use. Mr. Kraut explained that the site plans have been revised to provide a plastic pervious material for the 12 angled parking spaces, replacing the previously proposed grasscrete.

 Mr. Kraut responded to neighbor concerns raised at the previous Planning Commission meeting regarding the visual impact of the expanded parking area.
 Mr. Kraut explained that the expanded parking area will not result in the loss of existing vegetation and that substantial white pines exist along the property line closest to the expanded parking area. Mr. Kraut stated that the applicant has

December 14, 2004 Page 3 of 8

1 2 3

10 11 12

13 14 15

16

222324

25 26

27282930

31

40 41 42

38 39

agreed to provide 3 to 4-foot high evergreen shrubs along the property line to provide a visual screen.

- The Commission expressed concern with the extent and intensity of lighting on the property and whether more lighting could be turned off during periods when the Synagogue is not in use. Mr. Kraut explained that the site plan resolution allows the applicant to keep lights on for security purposes during evening hours. Mr. Kraut explained that the Synagogue is a sensitive religious use and requires extra security measures but that he will review the lighting provisions with the Synagogue to see that lighting could be reduced to the lowest possible level.
- The Planning Commission noted the location of a shed within the wetland buffer and recommended that it be relocated outside of the 100-foot regulated area.
- The Planning Commission noted the receipt of comments from the CC/AC and requested that they be released to the applicant. The Planning Commission noted that the CC/AC comments include concerns with the application but they were submitted substantially after the required 30-day comment period. Mr. Kraut agreed to review the comments of the CC/AC and revise the plans for the maximum extent possible.

3. Colahan Subdivision

- The Planning Commission reviewed the applicant's drainage plan with the City Engineer. Mr. Mottarella stated that the applicant applied the appropriate drainage criteria and followed the City's standards but that evidence of percolation tests was not provided. Mr. Mottarella requested that actual percolation test results be used as part of the applicant's analysis, rather than an assumed rate.
- Commission questioned whether footing drains would be provided for the proposed residence. Rex Gedney (applicant's architect) explained that footing drains may be provided since the first floor elevation would be at 35, the cellar elevation would be at 26 and the deep hole tests indicated no water 8 feet below existing grade. Mr. Gedney stated that footing drains may be able to gravity flow towards subsurface dry wells.
- The Planning Commission questioned the drainage provisions for the existing residence. Mr. Gedney stated that the existing residence had some dry wells on the property. The Planning Commission requested that the location of existing dry wells be shown on the plan.
- The Planning Commission noted concern of the visual impact of the proposed driveway for the existing residence. The Commission stated that the aesthetic concern is significant given the property's proximity to the existing Rye Town

December 14, 2004 Page 4 of 8

3 4

Park and the existing neighborhood character in this section of Forest Avenue. The Commission stated the proposed driveway would also impact an existing significant beech tree, which if lost, would also have an adverse character impact.

• The Commission stated that it would prefer a common driveway using the existing driveway on the property to serve as access to both lots to reduce the aesthetic impact of the proposed subdivision. Commission stated that the loss of existing trees along the side property line would be acceptable if it meant that the existing beech tree on the site could be preserved.

 The City Planner stated that if the Planning Commission chooses to require a common driveway that it would need to be wider (between 12 and 15 feet in width) in order to provide suitable access for two lots.

 Planning Commission stated concern with the available sight distance for the proposed driveway noting that a wall would be required which could block a drivers view of oncoming traffic or pedestrians.

• Rex Gedney (applicant's architect) stated that the aesthetics concern could be addressed with an alternative paving material and that the proposed wall is only 4 feet high and would not block vehicle sight distance. Mr. Gedney added that a common driveway would double the existing traffic on the driveway closest to an abutting neighbor and approximately 80 feet from the intersection of Forest Avenue and Oakland Beach Avenue. Mr. Gedney added that there are existing pillars and a wall at the current access drive that may also serve to obstruct vehicle sight distance, which the Commission should consider.

• The Planning Commission requested that the applicant review the traffic safety and vehicle sight distance concerns at the existing and proposed driveway.

 The Planning Commission stated that it will defer setting the public hearing on this matter until an alternative driveway configuration is provided for its review.

4. Lombardi and Sinis Subdivision

• The Commission reviewed the proposed drainage measures with the applicant and City Engineer. The City Engineer requested that the drainage analysis be revised to comply with the City's criteria. The City Engineer stated that the results of the percolation tests should be provided in the applicant's submission. City Engineer requested that the applicant comply with the requirements of the Phase II stormwater quality requirements.

December 14, 2004 Page 5 of 8

- City Engineer agreed that there would be no adverse impact on down stream properties on Morris Court from the proposed subdivision. City Engineer noted that all driveway runoff would be intercepted by proposed trench drains and directed toward on site drywells.
- Planning Commission requested that the extent of tree removal within the Morris Court right of way be shown on the subdivision plans.
- The Planning Commission requested that the applicant's sight distance analysis
 be revised to quantify the amount of sight distance provided at both driveway
 locations. The City Planner stated that the sight distance that is provided should
 be compared to criteria assuming a prevailing travel speed on Boston Post Road
 40 miles per hour. Planning Commission recognized that the relocation of the
 existing driveway appears to be an improvement but wanted that improvement
 quantified for the record.
- The Planning Commission discussed its desire to restrict the location and orientation of the proposed residence on lot 74C. The City Planner stated that special language within the resolution and conditions would be required to meet the Planning Commission's request.
- The Commission noted errors in the grading plan particularly for lot 74C and requested that the site plan be corrected including correcting the first floor elevation for the residence.
- The Planning Commission discussed the possibility of providing a landscape buffer along Boston Post Road to preserve the character of this roadway. The Commission agreed it would discuss this matter at a later date.

5. 259 Purchase Street

• There was no applicant representation for this matter. There was no discussion by the Planning Commission.

6. Yazigi Residence

- Joe Murphy (CC/AC chair) stated that the Conservation Commission would provide comments to the Planning Commission.
- The Planning Commission requested that the applicant consider alternatives to reduce the extent of increase in the 100-foot wetland buffer. The Commission noted that the proposed increase in impervious area of 1,400 square feet was substantial and should be reduced.

December 14, 2004 Page 6 of 8

- 1 2 3 4
- 5 6
- 7 8 9 10 11
- 12 13 14
- 16 17 18

19

20

15

- 21 22 23 24
- 25 26 27 28

29

35

36 37

38

39

40

41 42 43

44 45

- The Planning Commission noted that it conducted a site walk of the property and observed a wetland area that appeared larger than that shown on the site plans. The Planning Commission requested that a wetland delineation be conducted for this property.
- Richard Horsman (applicant's landscape architect) stated that a wetland delineation would be provided. Mr. Horsman stated that the applicant acknowledges the location of the wetland on or near the property and that a wetland mitigation plan has been provided to improve stormwater quality runoff. Mr. Horsman stated that the wetland appears to be surface flow from an unknown source along the side property line.
- The Planning Commission requested that the applicant consider alternatives such as using the existing driveway and garage to meet the applicant's needs while minimizing the impact on the wetland and its adjacent buffer.

7. Callund Residence

- The Planning Commission noted that the application was presented to the Commission as a result of a complaint and a stop work order issued by the City of Rye in connection with tree removal and site disturbance activities on the applicant's property.
- The Planning Commission noted that it conducted a site walk and questioned the size and configuration of the wetland on the site plan. The Commission requested that a more detailed wetland delineation be provided.
- Richard Horsman (applicant's landscape architect) stated that he would provide more information regarding the wetland delineation. Mr. Horsman provided an overview of the drainage on the property noting that it comes from adjacent properties across the applicant's property to an existing storm water pipe that goes under Manursing Road. Mr. Horsman stated that the low-lying area on the property near the existing pipe under Manursing Road collects water causing a wetland to form.
- Mr. Callund (property owner) stated that his property has a peculiar shape and wanted to use the only available area on this site for a managed lawn and play area. Mr. Callund stated he wanted to turn the existing garage to a day room and construct new-detached garage. The Planning Commission requested that the applicant provide soil test results delineating the boundary of the wetland and that the number and size of the trees removed on the property be indicated. This information will be used to confirm whether a violation of the City 's wetland law has occurred.

8. 64 Purchase Street

December 14, 2004 Page 7 of 8

• David Mooney (applicant's architect) stated that the applicant intends to demolish an existing building and construct a new 2-story building. Two retail spaces would be provided on the first floor and two professional office tenants would be created on the second floor.

• The Planning Commission requested that the proposed doors on the side of the building be modified so that they do not swing into the adjacent pedestrian easement area.

 The Planning Commission requested that the applicant re-think the size and location of the proposed dumpster in the rear of the property. The Commission noted that given the number of tenants that a larger dumpster area would be required and should be more accessible to all proposed tenants. The dumpster space should also be appropriately screened so as to not compete with the proposed rear storefront façade facing the City car park.

• The City Engineer requested that the applicant determine whether there is an existing City drain line under the existing building. If such a drain line exists there should be consideration to relocate this drain line to a City easement.

• The Planning Commission requested that the applicant provide a description of the easement terms and conditions.

9. Dogan Residence

The City Engineer and the Planning Commission expressed concern about the proposed basement and drainage plan. The Commission stated that the basement elevation would be below that of the adjacent pond and could resolve in the draining of the wetland through the footing drain. The City Engineer added that extending a new drain line in Sharon Lane would not be desirable since existing storm drains down stream have limited capacity and known drainage problems. The City Engineer suggested that a more appropriate concept would be to direct all storm water generated from the site towards the existing pond. New dry wells or other water quality measures should be provided to treat the first flush of pollutants.

 The Planning Commission and the City Engineer stated that a basement would have an adverse impact on the pond as well as possible construction concern involving rock removal and should not be provided.

 The applicant stated that it was seeking a variance from the zoning code provision that restricts the first floor elevation of the residence to no more than

December 14, 2004 Page 8 of 8

1

2 3 4

10 11

12

13

14

20

25 26 27

28

three feet above pre-existing grade. Ms. Dogan stated that the variance was needed to provide a better view of the pond.

- The Planning Commission noted the substantial increase in impervious area on the site and recommended that the extent of the impervious area be reduced. The Commission noted that the applicant should not take credit in the calculation of the increase in impervious area of existing ledge rock on the site. The Commission noted that based on current information providing the required 2 to 1 wetland mitigation plantings could be difficult to achieve.
- Sid Burke (applicant's landscape architect) discussed the concept for wetland mitigation plantings and suggested that requiring the 2 to 1 standard was not necessary given that roofs and patios do not generate pollution loadings that require mitigation. The City Planner responded that the site includes a number of environmental constraints and that the increase in impervious area is a way for the Commission to evaluate the extent of the disturbance on the site within close proximity to a water body. The Commission and the City Planner stated that the 2 to 1 mitigation standard is repeatedly required by the Commission and should be met for this property.
- The applicant clarified extent of floor area ratio variance that would be required for the proposed residence. The applicant stated that it would exceed permitted FAR limitation by approximately 350 feet.
- The Commission agreed that given the environmental constraints on the property, that an alternative plan be presented for its review.